

Lithium Iron Phosphate Battery Specification

Customer _____

Part name Rack-Mounted Battery

Model No PKG-RM48100-S-ACA (DRBMS)

Approved by		Drafted by	Xiaojun Nie
Checked by		Signed by	Wenfei Liang
Prepared by		Date	2023-04-23

Company address: 7th Floor, block B, Yicheng Huanzhi center, Renmin Road, Longhua District, Shenzhen, China.

(Tel) : +86-755-86670672

(Fax) : +86-755-86670609

E-mail: sales@pkenergy.com Website: <http://www.pkenergy.com>

Product Modified Record List

Revision	Date	Modified Content	Corrected person
A1	2023-04-23		

2 If manufacturer want to modify the product technology specification, we won't inform you additionally)

1. Scope 适用范围

The specification shall be applied to LiFePO4 rechargeable battery pack Of PKG-RM48100-S-ACA which is manufactured by SHENZHEN PKENERGY ENERGY CO.,LTD

本规格书适用于深圳市倍苛新能源有限公司生产的 PKG-RM48100-S-ACA 机架式储能电源。

2. Battery Pack specifications 电池组技术参数

	No.	Item	General Parameter		Remark
	(序号)	(项目)	(常规参数)		(备注)
Package 电池组	1	Combination method (组合方式)	15S1P		48V 100Ah
	2	Rated Capacity (额定容量)	Typical (标称容量)	100Ah	Standard discharge after Standard charge (package) (标准充电后标准放电 (针对电池组))
			Minimum (最小容量)	98Ah	
	3	Factory Voltage (出厂电压)	48V-50V		
	4	Voltage at end of Discharge (放电终止电压)	41V		Discharge Cut-off Voltage (放电截止电压)
	5	Charging Voltage (充电电压)	54V		
	6	Internal Impedance (内阻)	≤20mΩ		Internal resistance measured at AC 1KHZ after 50% charge (半电态下用交流法测量内阻) The measure must uses the new batteries that within one week after shipment and cycles less than 5 times (使用出货后不到一个星期及循环次数少于 5 次的新电池测量)
	7	Standard charge (标准充电)	Constant Current: 20A-100A Constant Voltage see No. 5 0.02C cut-off (持续电流: 20A-100A 持续电压: 见序号5, 截止电流: 0.02C)		Charge time : Approx 1.5-6 h (充电时间: 大约1.5-6个小时)
	8	Standard discharge (标准放电)	Constant current: 20A-100A end voltage see NO.4 (持续电流: 20A-100A 截止电压: 见序号4)		
	9	Maximum Continuous Charge Current (最大充电持续电流)	100A		T ≥ 10°C
10	Maximum Continuous Discharge Current	100A		T ≥ 10°C	

3 If manufacturer want to modify the product technology specification, we won't inform you additionally)

	(最大放电持续电流)		
11	Operation Temperature Range (工作温度范围)	Charge (充电) : 0~45°C	60± 25%R .H. Bare Cell (单体电池储存湿度范围)
		Discharge (放电) : -20~60°C	
12	Storage Temperature Range (储存温度范围)	Less than 12 months : - 10~35°C (小于 12 月: -10~35°C)	60± 25%R .H. at the shipment state (出货状态时的湿度范围)
		less than 3 months: -10~45°C (小于 3 个月: -10~45°C)	
		Less than 7 day : -20~65°C (小于 7 天: -20~65°C)	
13	Dimensions (尺寸)	460*442 (含挂耳 482) * 177mm	
14	Weight (重量)	Approx: ≈42kg	供参考, 以实际为准
15	Cycle Life	6000cycles@25°C	Based On 90% DOD
16	Design Life	≥10Years	Based On 25°C

3.BMS function introduction BMS 功能介绍

The BMS is designed for 15/ 16 series lithium battery. (BMS 为 15/16 串锂离子电池设计)

The BMS have all functions which are : (该 BMS 系统具有 以下一些功能)

overcharge detection function (过充电保护功能)

over discharge detection function (过放电保护功能)

over current detection function (过电流保护功能)

short detection function (短路保护功能)

Temperature detection function (温度保护功能)

balance function (均衡功能)

communicate function (通讯功能)

Alarm function (告警功能)

Total capacity function (总容量功能)

Storage history function (存储历史记录功能)

3.1 BMS Protect parameter 电池管理系统保护参数


Items	Details	Standard
Cell overcharge protection	Overcharge detection voltage	3.65±0.025V
	Overcharge detection delay time	Typical:1.0s
	Overcharge release voltage	3.38±0.02V
Cell over-discharge protection	Over-discharge detection voltage	2.7±0.02V
	Over-discharge detection delay time	Typical:1.0s
	Over-discharge release voltage	2.95±0.02V
Over-current protection	discharge Over-current protection current1	110A
	discharge Over-current detection delay time 1	1S
	discharge Over-current protection current 2	150A
	discharge Over-current detection delay time 2	≤200m±50ms
	Charge OC protection current	110A
Short protection	Short protection current	350A
	Protection condition	Load short
	Detection delay time	≤30ms
	Protection release condition	Charging release
Temperature(T) protection	Charge high T protection	55±3℃
	Charge high T recover	47±4℃
	Discharge high T protection	60±3℃
	Discharge high T recover	50±4℃
	Charge low T protection	0±3℃
	Charge low T recover	5±4℃
	Discharge low T protection	-20±3℃
	Discharge low T recover	-10±4℃
Balance	Balance threshold voltage	3.45V
Communication	It has RS232 /RS485 and canbus standard communication interface, it can real-time monitoring the capacity of battery bank, the voltage, current, environment temperature, and charging/discharging current.	
Alarm	It has over-temperature, over charge, under-voltage, over-current, short circuit alarm Function.	

4. Appearance and structural dimensions 外观 结构尺寸


There shall be no such defect as scratch, bur and other mechanical scratch, and the connector should be no rust dirt. The structure and dimensions see attached drawing of the battery.

电池的 表面应无明显的划痕毛刺及其其它机械划伤，外露的金属端子应无锈蚀污垢。

电池外形图：



5. Parallel machine connection 并机联接



6 If manufacturer want to modify the product technology specification, we won't inform you additionally)

6. Communication interface 通信接口

具有与上位机通讯的 RS485 接口;具有 CAN 接口, 可以进行多机并联通讯。(RS485 波特率 19200,CAN 波特率 500K)

RS485 interface for communication with upper computer;With CAN interface, CAN carry out multi-machine parallel communication.(RS485 baud rate 19200,CAN baud rate 500K)

逆变器通信协议选择: (Communication protocol selection of inverter)


当主机(拨码地址 1、2、3、4 是 OFF 时)CAN 才能与逆变器通信, 当拨码 6 为 on 时能支持派能系, 拨码 5 和 6 为 on 时 目前支持古瑞瓦特协议。

When the host (the dialing address 1、2、3 and is OFF) CAN communicates only with the

inverter, when the code 6 is on, it can support the pylontech protocol, the code 5 and 6 are on, it supports the Guerrero watt protocol.

RS485 / CAN 接口定义

(转接灯板 CAN/RS485A/RS485B 网口定义相同, 如下)



引脚	定义
1、3、8	RS485-B
2、7	RS485-A
6	GND
4	CANH
5	CANL

网线说明:

1、单独 CAN 网线 Separate CAN network cable: 1/2/3/6/7/8 NC,4-CANH 5-CANL

2、RS485A RS485B 并机网线 The RS485A RS485B parallel network cable : 1/3/8 RS485-B,2/7 RS485-A,6- GND,4/5 NC


3、RS485 和 CAN 兼容网线 RS485 and CAN compatible network cable: 1/3/8 RS485-B,2/7 RS485-A,6-GND,4- CANH 5-CANL (Host line)

并机接口 Parallel interface

BMS 电池包间通过 RS485 总线并联通讯，可与具有 RS485 总线的设备通讯，而 CAN 接口实现与 PC 或者其它智能终端通讯，人机交互 RS485 总线所并联的任一电池包信息，多机并联总线接口见下图所示。（支持派能和固德威协议）

BMS battery packs communicate in parallel via RS485 bus, and can also communicate with devices with RS485 bus, while RS232 interface realizes communication with PC or other intelligent terminals, human-computer interaction RS485 bus parallel connection of any battery pack information, multi-machine parallel bus interface See the figure below.

(The supporters can make a deal with Goodway)



主机设置与 PC 端通信 Host setting and PC communication

主机设置：拨码开关 6 设置为 ON，为主机（只能设置 1 个主机），CAN 线只接主机 BMS，可以通过 CAN 与逆变器端进行通信。

主机与终端通信示意图：

Schematic diagram of communication between host and terminal:





地址拨码开关 Dip switch

拨码设置 Switch setting

在进行多机并联通讯操作时，需要先进行各 PACK 的拨码地址配置。拨码采用 BCD 码格式，地址为 0 的定义为



（黑点是 OFF 状态，空白是 ON 状态，以下同），

地址 1  , 地址 2 



二进制算法，其他地址以此类推。

In the multi-machine parallel communication operation, you need to configure the DIP address of each PACK first. The DIP code adopts

the BCD code format, the address of 0



is defined as (black dot is OFF state, blank is ON state,thesa me below) ,

address 1  , address 2  , andsoon.

从机设置 (表 1)

地址	拨码开关位置				预留	主机	说明
	#1	#2	#3	#4			
0	OFF	OFF	OFF	OFF	OFF	OFF	(从机) Pack0
1	ON	OFF	OFF	OFF	OFF	OFF	(从机) Pack1
2	OFF	ON	OFF	OFF	OFF	OFF	(从机) Pack2
3	ON	ON	OFF	OFF	OFF	OFF	(从机) Pack3
4	OFF	OFF	ON	OFF	OFF	OFF	(从机) Pack4
5	ON	OFF	ON	OFF	OFF	OFF	(从机) Pack5
6	OFF	ON	ON	OFF	OFF	OFF	(从机) Pack6
7	ON	ON	ON	OFF	OFF	OFF	(从机) Pack7
8	OFF	OFF	OFF	ON	OFF	OFF	(从机) Pack8
9	ON	OFF	OFF	ON	OFF	OFF	(从机) Pack9
10	OFF	ON	OFF	ON	OFF	OFF	(从机) Pack10
11	ON	ON	OFF	ON	OFF	OFF	(从机) Pack11
12	OFF	OFF	ON	ON	OFF	OFF	(从机) Pack12
13	ON	OFF	ON	ON	OFF	OFF	(从机) Pack13
14	OFF	ON	ON	ON	OFF	OFF	(从机) Pack14
15	ON	ON	ON	ON	OFF	OFF	(从机) Pack15
协议选择说明							
32	OFF	OFF	OFF	OFF	OFF	ON	CAN 接口
48	OFF	OFF	OFF	OFF	ON	ON	CAN 接口

7. Battery test equipment 电池测试设备

7.1 Dimension Measuring Instrument 尺寸测量仪器

The dimension measurement shall be implemented by instruments with equal or more precision scale of 0.1mm. 测量尺寸的仪器的精度应不小于 0.1mm

7.2 Voltmeter 电压表

Standard class specified in the national standard or more sensitive class having inner impedance not less than 10 K Ω /V. 国家标准或更灵敏等级, 内阻不小于 10 K Ω /V.

7.3 Ammeter 电流表

Standard class specified in the national standard or more sensitive class. Total external resistance including ammeter and wire is less than 0.01 Ω .

国家标准或更灵敏等级, 外部总内阻包括电流表和导线应小于 0.01 Ω .

7.4 Impedance Meter 内阻测试仪

Impedance shall be measured by a sinusoidal alternating current method(AC 1 kHz LCR meter). 内阻测试仪测试方法为交流阻抗法(AC 1kHz LCR).

7.5 Standard Test Condition 标准测试条件

Test should be conducted with new batteries within one month after shipment from our factory and the cells shall not be cycled more than five times before the test. Unless otherwise defined, test and measurement shall be done under temperature of 23 \pm 2 $^{\circ}$ C and relative humidity of less 75%., air 86Kpa~ 106Kpa.

测试电池必须是本公司出厂时间不超过一个月的新电池, 且电池未进行过五次以上充放电循环。除非其它特殊要求, 本产品规格书规定的测试的环境条件为: 温度 23 \pm 2 $^{\circ}$ C, 相对湿度 \leq 75%, 气压 86Kpa~ 106Kpa.

Unless otherwise defined, 30 min, rest period after charge, 30 min, rest period after discharge. 如无特殊要求, 电池充放电间隔为 30min.

8. Storage and Others 贮存及其它事项

8.1 LongTime Storage 长期贮存

If stored for a long time (don't used, exceed three months), the cell should be stored in drying and cooling place. The cell's storage voltage should be 48.0V-51.0V and the cell is to be stored in a condition that the temperature of 23 \pm 2 $^{\circ}$ C and the humidity of 45%-75%. Long-term use of unused batteries to recharge every 3 months. Ensure that the battery voltage is within the above range. 长期贮存的电池(未使用, 超过 3 个月)须置于干燥、凉爽处。贮存电压为 48.0V-51.0V。储存于 23 \pm 2 $^{\circ}$ C, 湿度为 45%-75%的洁净环境。长期搁置未使用电池每 3 个月补电一次, 确保电池电压在上述范围内。

8.2 Others 其它事项

Any matters that this specification does not cover should be conferred between the customer and SHENZHEN PKENERGY ENERGY CO.,LTD

任何本规格书中未提及的事项, 须经双方协商确定

9. Amendment of this Specification 产品规格书的修订

This specification is subject to change with prior notice.

本公司有权对本产品规格书进行修订。

10. Appendix 附录

Handling Precautions and Guideline

For Li-ion Rechargeable Batteries

锂离子充电电池操作指示及注意事项

Preface 前言

This document of 'Handling Precautions and Guideline Li-ion Rechargeable Batteries' shall be applied to the battery cells manufactured by SHENZHEN PKENERGY ENERGY CO.,LTD

本档“锂离子充电电池操作指示及注意事项”仅适用于深圳市倍苛新能源有限公司生产电池。

Note (1): 声明一

The customer is requested to contact SHENZHEN PKENERGY ENERGY CO.,LTD. in advance, if and when the customer needs other applications or operating conditions than those described in this document. Additional experimentation may be required to verify performance and safety under such conditions.

客户若需要将电池用于超出本规格书规定以外的设备，或在本规格书规定以外的使用条件下使用电池，应事先联系深圳市倍苛新能源有限公司，因为需要进行特定的实验测试以核实电池在该使用条件下的性能及安全性。

Note (2): 声明二

SHENZHEN PKENERGY ENERGY CO.,LTD will take no responsibility for any accident when the cell is used under other conditions than those described in this Document.

对于在超出本规格书规定以外的条件下使用电池而造成的任何意外事故，深圳市倍苛新能源有限公司概不负责。

Note (3): 声明三

SHENZHEN PKENERGY ENERGY CO.,LTD will inform, in a written form, the customer of improvement(s) regarding proper use and handling of the cell, if it is deemed necessary.

如有必要，深圳市倍苛新能源有限公司会以书面形式告知客户有关正确操作使用电池的改进措施。

Danger!

危险!

— Do not immerse the battery in water or allow it to get wet.

— 勿将电池投入水中或将其弄湿!

— Do not use or store the battery near sources of heat such as a fire or heater.

— 禁止在火源或极热条件下给电池充电! 勿在热源 (如火或加热器) 附近使用或贮存电池! 如果电池泄漏或发出异味, 应立即将其从接近明火处移开;

— Do not use any chargers other than those recommended by SHENZHEN PKENERGY ENERGY CO.,LTD.

— 请使用专用充电器!

— Do not reverse the positive(+) and negative(-) terminals.

— 勿将正负极接反!

— Do not connect the battery directly to wall outlets or car cigarette-lighter sockets.

- 勿将电池直接连接到墙上插座或车载点烟式插座上！
 - Do not put the battery into a fire or apply direct heat to it.
 - 勿将电池投入火中或给电池加热！
 - Do not short-circuit the battery by connecting wires or other metal objects to the positive(+) and negative(-) terminals.
 - 禁止用导线或其它金属物体将电池正负极短路，禁止将电池与项链、发夹或其它金属物体一起运输或贮存！
 - Do not pierce the battery casing with a nail or other sharp object, break it open with a hammer, or step on it.
 - 禁止用钉子或其它尖锐物体刺穿电池壳体，禁止锤击或脚踏电池！
 - Do not strike, throw or subject the battery to sever physical shock.
 - 禁止撞击、投掷或者使电池受到机械震动
 - Do not directly solder the battery terminals.
 - 禁止直接焊接电池端子！
 - Do not attempt to disassemble or modify the battery in any way.
 - 禁止以任何方式分解电池！
 - Do not place the battery in a microwave oven or pressurized container.
 - 禁止将电池置入微波炉或压力容器中！
 - Do not use the battery in combination with primary batteries(such as dry-cell batteries) or batteries of different capacity, type or brand.
 - 禁止与一次电池（如干电池）或不同容量、型号、品种电池组合使用！
 - Do not use the battery if it gives off an odor, generates heat, becomes discolored or deformed, or appears abnormal in any way.
- If the battery is in use or being recharged, remove it from the device or charger immediately and discontinue use.
- 如果电池发出异味、发热、变形、变色或出现其它任何异常现象时不得使用；如果电池正在使用或充电，应立即从用电器中或充电器上取出并停止使用！

Caution!

注意！

Do not use or store the battery where is exposed to extremely hot, such as under window of a car in direct sunlight in a hot day. Otherwise, the battery may be overheated. This can also reduce battery performance and/or shorten service life.

不要使用处于极热环境中的电池，如阳光直射或热天的车内。否则，电池会过热，可能着火（点燃），这样就会影响电池的性能、缩短电池的使用寿命。

If the battery leaks and electrolyte gets in your eyes, do not rub them. Instead, rinse them with clean running water and immediately seek medical attention. If left as is, electrolyte can cause eye injury.

如果电池漏液后电解液进入眼睛，不要擦，应用水冲洗，立即寻求医疗救助。如不及时处理，眼睛将会受到伤害。

.....EDN.....